


	DECLARATION OF PERFORMANCE		No. PIRO-06-2018-09-10	Date: 30/09/2020
1	Unique product identification code:		PiroCoating (coating), PiroCoat I (paste), PiroCoat A (paste)	
2	Intended use:	for fire stopping and fireproof sealing, mineral wool insulation in mixed penetrations in walls and floors, restoring fire resistance of walls and floors		
2 a	floors with a width from 150 mm (reinforced concrete) Rigid walls with a width from 100 mm (aerated concrete, brick, reinforced concrete) Flexible walls with a width of 100mm or more (plasterboard, wood)			
3	Manufacturer: Pirosystem Sp. z o.o. ul. Ogrodnicza 3A, 83-021 Wiślina, POLAND			
4	Authorised Representative: Pirosystem Sp. z o.o. ul. Ogrodnicza 3A, 83-021 Wiślina, POLAND			
5	Assessment and verification of constancy of performance			SYSTEM 1
6a	Harmonised standard Specified in point 2 and point 7			
6b	European Assessment Documents	ETA-17/1062	of 2020-09-17	Notified Body Number 1488
7	Declared performance, fire safety			
	Reaction to fire class		B-s2,d0	
	Fire resistance		Do EI 120 lub EI 180	
	Declared performance hygiene, health, environment			
	Durability		Z2	
Release of dangerous substances (declaration). : product intended for outdoor or indoor use.				
8	Technical documentation: Technical Data Sheet, Pirosystem Sp. z o.o. Product Catalogue			
The performance of the described afore product corresponds to the declared performance. This declaration of performance has been issued in accordance with Regulation (EU) No. 305/2011 under the sole responsibility of the said manufacturer.				
Place, date of issue			Wiślina, 30/09/2020	
On behalf of the manufacturer, signed by			President of the Management Board Marcin Gierej Pirosystem sp. z o.o. ul. Ogrodnicza 3A 83-021 Wiślina nip 6040200582 regon 369982224 Prezes Zarządu Marcin Gierej 	

CE

1488

Pirosystem Sp. z o.o.
Ogrodnicza 3A, 83-021 Wiślina, POLAND

1488-CPR-0726/W

PN-EN 1366-3:2010
Fire protection of buildings
Fire resistance testing method for installation sealing systems

The logo for PIROSYSTEM features a stylized 'P' on the left, composed of two overlapping curved shapes in shades of orange and yellow. To the right of this 'P' is the word 'PIROSYSTEM' in a bold, black, sans-serif font. A red circle with a white center is positioned to the left of the 'P', partially overlapping the 'I'. The entire logo is set against a background of large, faint, grey letters 'PFP'.

Classification
EI 120 (walls)
EI 180 (floors)

PASSIVE FIRE PROTECTION